

WATER SAMPLE ANALYSIS

| Client Name and Site Address NHS Lothian Special Care Baby Unit St. John's Hospital | | Report To: Ian Strachan Surveyor: John A Bryson | | Job No.: 70524 Page No. 1 of 1 |
|---|---|--|---|--|
| Sampling Date 10/03/2020 | Date to Lab 10/03/2020 | Analysis Commenced 11/03/2020 | Analysis Completed 13/03/2020 | |
| Analysis performed at Westfield Caledonian's UKAS accredited testing laboratory No. 4042 | | | | |
| Sample No. | Source Description | Pseudomonas aeruginosa (cfu/100ml) | | |
| 1 | Panda Pad Gas Room WHB Mixer Pre-Flush | <1 | | |
| 2 | Panda Pad Gas Room WHB Mixer Post-Flush | <1 | | |

GUIDE LEVELS

Pseudomonas aeruginosa should not be present (i.e. <1cfu per 100ml).