

WATER SAMPLE ANALYSIS

Client Name and Site Address NHS Lothian Wallace Burns Unit St. John's Hospital		Report To: Ian Strachan Surveyor: John A Bryson		Job No.: 70549 Page No. 1 of 1
Sampling Date 07/04/2020	Date to Lab 07/04/2020	Analysis Commenced 07/04/2020	Analysis Completed 09/04/2020	
Analysis performed at Westfield Caledonian's UKAS accredited testing laboratory No. 4042				
Sample No.	Source Description	Pseudomonas aeruginosa (cfu/100ml)		
1	Arjo Bath Spray Head Pre-Flush	<1		
2	Arjo Bath Spray Head Post-Flush	<1		

GUIDE LEVELS

Pseudomonas aeruginosa should not be present (i.e. <1cfu per 100ml).